

# Agrichemical Warehousing Standard Association

## ACCREDITED SEED TREATMENT STANDARDS BULLETIN

Revised: April 2016

NUMBER: 2

### Fire Separation Requirements for Storage and/or Treatment Areas Enclosed Within Multiple Occupancy Buildings (Relating to Protocols B1 & B2)

Protocols B1 and B2 outline structural requirements for Storage (B1) and Seed Treatment (B2) areas. This bulletin is provided to clarify the fire separation requirements when storage and/or seed treatment areas are housed within a building with multiple occupancies.

Protocol B1 states:

*The **storage area(s)**, if enclosed within a building, must be separated from other occupancies by a permanent two-hour fire separation. Interior fire compartment separation wall openings are provided with self-closing doors and if applicable, fire dampers having resistance rating of 1.5 hours, including the frames.*

The definition of “other” occupancies could include the following: offices, maintenance shops, lunchrooms, or other areas, which may be physically occupied. This excludes occupancies associated with seed (treated or untreated) handling/storage processes.

Examples of incompatible occupancies/equipment include:

- Storage of power tools and/or storage of fuel powered equipment (which contain fuel)
- Sales/mercantile areas
- Feed storage

Protocols B2 states:

*The **seed treatment area(s)**, if enclosed within a building, must be separated from other occupancies by a permanent two-hour fire separation. Interior fire compartment separation wall openings are provided with self-closing doors and if applicable, fire dampers having resistance rating of 1.5 hours, including the frames.*

*The seed treatment areas pre-audited prior to March 31, 2015 can be grandfathered and exempted from this provision, with the exception of offices, lunchrooms and maintenance shops*

The definition of “other” occupancies could include the following: offices, maintenance shops, lunchrooms, or other areas which may be physically occupied. This excludes occupancies associated with seed (treated or untreated) handling/storage processes.

Examples of incompatible occupancies/equipment include:

- Storage of power tools and/or storage of fuel powered equipment (which contain fuel)
- Sales/mercantile areas
- Feed storage

*AWSA and the CropLife Canada, their employees, members or agents have neither made, nor do not hereby make, any representation, warranty or covenant with respect to the specifications, information and recommendations in this bulletin, or the results generated by their use, nor will they be liable for any damage, losses or claims, including those of an incidental or consequential nature, arising out of the use or inability to use this bulletin. Use of trade name implies neither endorsement of products, nor criticism of similar ones not mentioned.*

The seed treatment areas pre-audited prior to March 31, 2015 can be grandfathered and exempted from this provision, with the exception of offices, lunchrooms and maintenance shops.


Seed treatment areas pre-audited prior to March 31, 2015 can be also grandfathered to allow for seed cleaning activities in the same area as the seed treatment area. Sites not grandfathered require separation, as outlined in Protocol B2, between the seed cleaning area and the seed treatment area.

Note: If the seed treatment area is seasonal, the storage area can be used for other purposes provided that no agrichemicals are present in the off-season. A SOP is required to evidence this procedure.

If as part of the seed treatment area there are augers (including belts) that protrude through established firewalls they will be viewed as exempt from requiring a damper or an alternative modification to achieve a fire rating.


Interpretation examples:

**Scenario 1:**




In this scenario, the exterior walls must be non-combustible or provide a minimum of a one-hour fire rating. A separate between the chemical storage area and seed treatment area is not required. Given the storage and treatment area is treated as one, the entire area must complete with the requirements for both storage and treatment.

**Scenario 2.**




In this scenario, the exterior walls must be non-combustible or provide a minimum of a one-hour fire rating. The wall between the Seed treatment area and the office must have a two-hour fire rating. The wall between the chemical storage area and seed treatment area is optional.

**Scenario 3.**




In this scenario, the exterior walls must be non-combustible or provide a minimum of a one-hour fire rating. A two-hour fire separation is required between the office area and the chemical storage area. A two-hour fire separation is also required to separate chemical storage area from the general storage area. This division can be the wall between the chemical storage area and the seed treatment area if the site is grandfathered. If the site is not grandfathered, a two-hour fire separation is required between the seed treatment area and the general storage area.

**Scenario 4.**



In this scenario, the exterior walls must be non-combustible or provide a minimum of a one-hour fire rating. A two-hour fire separation is required between the office/Mercantile area and the chemical storage/treatment area.

**Scenario 5.**



In this scenario, the exterior walls must be non-combustible or provide a minimum of a one-hour fire rating. A two-hour fire separation is required between the general warehouse/mercantile area and the chemical storage area. The ceiling of the storage room would require a two hours fire rating (both sides).

*AWSA and the CropLife Canada, their employees, members or agents have neither made, nor do not hereby make, any representation, warranty or covenant with respect to the specifications, information and recommendations in this bulletin, or the results generated by their use, nor will they be liable for any damage, losses or claims, including those of an incidental or consequential nature, arising out of the use or inability to use this bulletin. Use of trade name implies neither endorsement of products, nor criticism of similar ones not mentioned.*

## Construction Scenarios.

Question/Scenario	Answer/Interpretation
Structural Steel framed warehouse. Does the addition of spray foam installation affect the fire rating of the wall assembly?	Documentation is required to evidence the fire rating of the spray foam installation.
For a wall assembly separating a mercantile area and a seed treatment and/or storage areas, is fire rating required on both side of the wall?	Fire rating is required on both sides of the wall
For a 1 or 2 hour fire wall assembly that is constructed of metal frame and drywall, does the additional of plywood to the drywall (to product from damage) affect the fire rating of the wall?	Yes, the plywood would lessen the fire rating of the wall assembly.
When a treatment area is enclosed within a building and there is an opening through which an auger runs to load trucks outside, what is required to maintain a 1-hour fire rating?	Exterior doors and windows do not require fire rating; consequently rating around pass through is not required. Fire rating would be required for openings in interior fire separation walls.
For interior firewalls – how high must they be?	For interior fire walls, the 2 hours wall assembly must go up to the roof, unless the storage and/or treatment areas are fire compartments (i.e. the walls and the ceiling have a two hour rating (see scenario #5)).